

REQUEST FOR PROPOSAL

RFP-26-03 DESIGN BUILD - INCLUSIVE & ACCESSIBLE PLAYGROUND

ADDENDUM #1



TOWN OF AMHERST



ADDENDUM #1

This Addendum forms part of the Request for Proposal (RFP) for the Design Build – Inclusive & Accessible Playground project and shall be incorporated into and become part of the Contract Documents. Proponents must acknowledge receipt of this Addendum in their submission.

This Addendum is issued to provide clarification on spatial requirements, material expectations, and design intent.

Q1. Regarding Appendix A for RFP-26-03. The drawings and information in the conceptual master plan are not legible as presented in the pdf document. Would it be possible to obtain a higher resolution document?

A1. Yes, if you would like a copy of the high-resolution conceptual master plan, please email your request to Aaron Bourgeois at abourgeois@amherst.ca

Q2. Is there a CAD file available that shows dimensions for the Beacons Street playground site plan?

A2. No.



Q3. Can the Town provide some basic square foot requirements? What area do we have to work within?

A3. The overall available area is approximately 2,600 square metres.





Q4. What does the Town have in mind for concrete/landscaping etc...

A4. The Town has not prescribed specific requirements for concrete or landscaping, and proponents are encouraged to develop these elements as part of their design in alignment with the overall project intent.

Q5. For lighting standards - do you want us to match existing lighting in the area/existing park?

A5. The Town has not prescribed a specific lighting standard, and proponents are encouraged to propose lighting that is appropriate for the space.

Q6. For the sheltered areas - does the Town have an idea of square footage for that?

A6. The primary shade structure should be approximately 400 square feet, the other shade areas, integrated into play zone, should be 100-200 square feet each.